_____2

2

1

Α

В

С

D

Е

1815



3

4

3

Λ

Sub-Metering Spatial Requirements Installation regulations for individual Cold Water Sub-Meters require 150mm clearance from the centre of each meter to other meters, walls or pipework. (Hot Water Meters require 200mm clearence centre to centre of other Hot Water Meters)

6

5



Notes All measurements are in mm.	Project SmartLink	Model No. SPAT
	Client	Description 1 - 4 C
	Contact	Created by
This drawing remains the property of deFOX I	ndustries Pty Ltd and may not be reproc	uced in full

6

5

1

